Rigging Guidelines and Specifications





Rigging Guidelines and Specifications



Contents

| 1. | OVERVIEW | 4 | | |
|------|---|------|--|--|
| 1.1. | In-House Rigging | 4 | | |
| 1.2. | Access Equipment | 4 | | |
| 1.3. | Outside Rigging Equipment | 4 | | |
| 2. | AUDITORIUM RIGGING | 5 | | |
| 2.1. | Rigging Diagram | 6 | | |
| 2.2. | Loading Restrictions | | | |
| | 2.2.1. Auditorium Load Capacity (Maximum Limits): | 6 | | |
| | 2.2.2. Auditorium Loading Points | 7 | | |
| 3. | EXHIBITION HALL RIGGING | 8 | | |
| 3.1. | Overview | 8 | | |
| 3.2. | Rigging – North and South Walls | 9 | | |
| 3.3. | Exhibition Loading Points | 9 | | |
| 4. | BANQUET ROOMS | 10 | | |
| 4.1. | Overview | . 10 | | |
| 4.2. | Loading Restrictions | . 10 | | |
| | 4.2.1. Banquet Room Loading Points | 10 | | |
| 5. | MEETING ROOMS | 11 | | |
| 5.1. | Overview | 11 | | |
| 5.2. | Loading Restrictions | 11 | | |
| | 5.2.1. Meeting Room Loading Points | 11 | | |
| 6. | PRE-FUNCTION AREAS | .12 | | |
| 6.1. | Overview | 12 | | |
| 6.2. | Loading Restrictions | 12 | | |
| | 6.2.1. Pre-Function Loading Points | 12 | | |
| APF | PENDIX A: RIGGING DIAGRAMS | .13 | | |

Rigging Guidelines and Specifications



| Dobson Rooms and Exhibition Hall Pre-Function Area | 13 |
|--|----|
| Banquet Halls and Exhibition Hall | 14 |
| Auditorium Pre-Function Area | 15 |
| Auditorium | 16 |
| Auditorium Stage House | 17 |

Rigging Guidelines and Specifications



1. OVERVIEW

Te Pae Christchurch Convention Centre is a fully equipped production venue with extensive rigging infrastructure to accommodate a wide range of events. This rigging manual outlines venue specific rigging plans and specifications. For further information please contact your dedicated Event Coordinator.

Te Pae Christchurch comprises three seismically separate buildings; the Auditorium, Exhibition Hall and Administration building. Within the public spaces of the Plenary and Exhibition Halls, steelwork is

provided to support a flexible arrangement of rigging including banners, lighting and sound systems.

Detailed rigging diagrams have been prepared showing the rating of each loading point. The following sections describe the key loading parameters and the associated limitations for each of the key spaces.

1.1. In-House Rigging

Te Pae Christchurch has a highly skilled, qualified and professional Audio-Visual (AV) Production team. Te Pae Christchurch's AV Production department has exclusive rigging rights in all spaces within the venue. All primary, bridling and secondary* rigging must be approved by the Te Pae Christchurch AV Production team.

*Te Pae Christchurch may authorise specific contractors to complete some secondary rigging, this must be authorised in writing by the Audiovisual Manager 14 days before event pack-in.

1.2. Access Equipment

Te Pae Christchurch has a full inventory of access equipment including scissor lifts, boom lifts and forklifts.

The venue has exclusive use of all equipment. Specific contractors can become authorised users for specific equipment by contacting Te Pae Christchurch's AV Production department.

Contractors will need to complete a comprehensive induction and will be issued with a venue and machine specific licence to be able to use Te Pae Christchurch machines in Te Pae Christchurch buildings.

1.3. Outside Rigging Equipment

On occasion, where Te Pae Christchurch may not have equipment capacity to meet a rigging request, the venue will organise external equipment from authorised suppliers.

Rigging Guidelines and Specifications



2.AUDITORIUM RIGGING

Te Pae Christchurch Convention Centre's Auditorium is fully equipped to host a range of different events. The Auditorium offers a full rigging system with a total load capacity of 32t.

The Auditorium is intended for hosting presentations and associated events. The inclined seating bowl faces a stage, and the rigging systems have been provided to accommodate a range of stage operational configurations, including division of the auditorium into two separate spaces.

Above the stage, an extensive rigging grid provides flexibility for rigging of video screens, stage lighting, loudspeakers, masking drapes, backdrops, etc. Discrete point loads can be suspended either from the overhead hoist beams, or directly from the rigging grid floor.

Figure 1 describes the general layout of the rigging steelwork provided, while Figure 2 outlines an indicative layout for the winch system that the rigging steelwork has been designed to accommodate.

The proscenium wall divides the main and forestage areas and extends below the stage rigging grid. While the wall has been designed to support motorised house curtains. A suspended catwalk is provided above the seating area to form a lighting bridge. The lighting bridge can be used to mount lighting systems from the points provided and provide a clear view of the stage.



Fig 1. Stage rigging grid – Structural Rigging Elements



2.1. Rigging Diagram



2.2. Loading Restrictions

The following describes the specific loading restrictions applicable to the Auditorium. These should be read

in conjunction with the Rigging Diagrams in Appendix A.

2.2.1. Auditorium Load Capacity (Maximum Limits):

Maximum load for Auditorium 1232,000 kg (total)Maximum load either side of centreline 1216,000 kg (total each side)

Notes:

- 1. Calculation of the loads applied must include the weight of all rigging elements (including chains, battens, trusses, spreader frames, hoists, winches, etc.
- 2. Calculation of the load applied to each side must include the sum of the reactions from all rigging elements within that side (including rigging points, hoist beams, winch system, etc. but excluding curtain beams).
- 3. Details of the various rigging points and load restrictions are provided on the Rigging Diagrams in Appendix A. Loads shall be suspended from the designated rigging locations only.
- 4. A summary of the various rigging locations is outlined in the table below.

Rigging Guidelines and Specifications



2.2.2. Auditorium Loading Points

| Loading Point | Location | Max Point Load ⁽¹⁾ | Load Limit ⁽¹⁾ | Bridling |
|----------------------------------|--------------------|-------------------------------|-------------------------------|---------------|
| Rigging Grid Floor | Bottom chord level | 100 kg | 280 kg/m ² | Not permitted |
| Diverter Beams | Top chord level | 250 kg | 500 kg/m ⁽⁶⁾ | Not permitted |
| Head Pulley Beams ⁽²⁾ | Top chord level | 1,000 kg | 2,500 kg/m ^(2,5) | Not permitted |
| Winch Beams (2) | Bottom chord level | 1,000 kg | 2,500 kg/m ^(2,3,4) | Not permitted |
| Hoist Beam Type 1 | Top chord level | 1,500 kg | 3,000 kg | Not permitted |
| Hoist Beam Type 2 | Top chord level | 1,500 kg | 3,000 kg | Not permitted |
| Hoist Beam Type 3 | Top chord level | 1,000 kg | 2,000 kg | Not permitted |
| Light Rigging Points | Catwalks | | 500 kg | Not permitted |
| Heavy Lighting Bars | Catwalks | 80 kg | 80 kg/m | Not permitted |
| Heavy Curtain Beam (6) | Proscenium wall | 30 kg | 30 kg/m | Not permitted |

1. All mechanical rigging systems must apply a dynamic factor of 1.2 or less.

2. If a proscenium curtain is suspended from any rigging element other than directly from the proscenium wall, the weight of the curtain must be included in the calculation of the total load supported by that rigging element with respect to the load limits outlined above.



3. EXHIBITION HALL RIGGING

3.1. Overview

The main Exhibition Hall comprises a series of roof trusses supporting a lightweight roof above. The room has no ceiling and is subdividable by operable walls that run along designated truss lines. A subdividable portion located at the western end comprises a lowered ceiling beneath the floor slab of the LO2 banquet room servery above.

Within the main hall the bottom chord of the trusses incorporates a series of discrete loading points (at approximately 9m x 8m centres) from which heavy loads can be suspended via hangers or bridles. The bottom chords of the trusses and the light rigging beams specifically identified on the rigging diagrams can be used for suspension of lighter items.

Beneath the trusses, curtain rails are provided around the perimeter of the Exhibition Hall, and along both sides of each operable wall. Lighting bars are also provided on the underside of the catwalks along the north and south walls of the Exhibition Hall. Figure 5-1 describes the layout of curtain rails and lighting bars along the north side of the Exhibition Hall behind the operable wall track.

In the lowered height portion in the Dobson Rooms a series of lighting bars and discrete loading points are provided in the ceiling.



3.2. Rigging – North and South Walls



Fig 3. Rigging at north and south walls of Exhibition Hall

3.3. Exhibition Loading Points

| Loading Point | Location | Load Limit ⁽¹⁾ | Bridling |
|----------------------|------------------------------------|---------------------------|---------------|
| Heavy Rigging Point | gging Point Bottom chord level 2 | | Not permitted |
| | | 1,000 kg | Up to 45° |
| Light Rigging Points | Lowered ceiling | 500 kg | Not permitted |
| Light Rigging Beam | Bottom chord level (2) | 200 kg | Not permitted |
| Medium Lighting Bar | Top chord level | 3,000 kg | Not permitted |
| Hoist Beam Type 2 | Under catwalks and lowered ceiling | 50 kg/m | Not permitted |
| Heavy Curtain Beam | Perimeter of Exhibition Halls | 30 kg/m | Not permitted |

1. All mechanical rigging systems must apply a dynamic factor of 1.2 or less.

2. The light rigging beams include the truss bottom chords and I-section beams specifically identified on the rigging diagrams only. With regards to the truss bottom chords, the 200 kg load limit applies to the unsupported span of the bottom chord between any two vertical web members. For clarity, loads cannot be suspended from the circular hollow sections or angles forming the bottom chord bracing plane.



4.BANQUET ROOMS

4.1. Overview

The Rivers Rooms and Conway Rooms located on Level One are provided with closely spaced rigging points (to provide flexibility) and a grid of lighting bars (to enable lighting of tables). The majority of the steelwork required to support these loads is suspended below bottom chord level.

4.2. Loading Restrictions

The following describes the specific loading restrictions applicable to the banquet rooms. These should be read in conjunction with the Rigging Diagrams in Appendix A.

Banquet Room Load Capacity (maximum limits):

Maximum load for Banquet Room_{1,2}10,000 kg (total)

Maximum load per truss 33,000 kg (total)

Notes:

- 1. This represents the total allowable load for the Waitaki Room. The total includes the sum of the loads suspended from both sub-dividable portions of the Waitaki Banquet Room.
- 2. This represents the total allowable load for the Rakaia Room. The total includes the sum of the loads suspended from each of the five sub-dividable portions of the Rakaia Room.
- 3. Calculation of the load applied to each truss must include the sum of the reactions from all rigging elements supported by that truss (including rigging points, lighting bars, etc).

Details of the various rigging points and load restrictions are provided on the Rigging Diagrams in Appendix A. Loads shall be suspended from the designated points only. A summary of the various loading points is outlined in below.

4.2.1. Banquet Room Loading Points

| Loading Point | Location | Load Limit ⁽¹⁾ | Bridling |
|----------------------|--------------------|---------------------------|---------------|
| Light Rigging Points | Bottom chord level | 500 kg | Not permitted |
| Medium Lighting Bar | Bottom chord level | 50 kg | Not permitted |

1. All mechanical rigging systems must apply a dynamic factor of 1.2 or less.



5.MEETING ROOMS

5.1. Overview

This section applies to the Bealey Rooms only (the level one meeting rooms are covered by the 'Banquet Rooms' section above, and the ground floor meeting rooms within the lowered ceiling portion of the Exhibition Hall are covered in 'Exhibition Hall' above).

Lighting bars are provided in the meeting rooms for flexible fixing of lighting, banners, etc. The location of the lighting bars are outlined in the Rigging Diagrams in Appendix A.

5.2. Loading Restrictions

The following describes the specific loading restrictions applicable to the Bealey Rooms. These should be read in conjunction with the Rigging Diagrams in Appendix A.

Loads shall be suspended from the designated points only. A summary of the various loading points is outlined in the table below

5.2.1. Meeting Room Loading Points

| Loading Point | Location | Load Limit ⁽¹⁾ | Bridling |
|---------------------|----------|---------------------------|---------------|
| Medium Lighting Bar | Various | 50 kg/m | Not permitted |

1. All mechanical rigging systems must apply a dynamic factor of 1.2 or less.



6.PRE-FUNCTION AREAS

6.1. Overview

The pre-function areas are provided with lighting bars in dedicated locations to enable lighting of key areas, or suspension of banners or similar. The locations of the lighting bars are outlined in the Rigging Diagrams in Appendix A.

6.2. Loading Restrictions

The following describes the specific loading restrictions applicable to the pre-function areas. These should be read in conjunction with the Rigging Diagrams in Appendix A. Loads shall be suspended from the designated points only. A summary of the various loading points is outlined in the table below.

6.2.1. Pre-Function Loading Points

| Loading Point | Location | Load Limit ⁽¹⁾ | Bridling |
|--------------------|-----------------------------|---------------------------|---------------|
| Light Lighting Bar | Various | 25 kg/m | Not permitted |
| Hanging Eyelet | Exhibition Hall upper level | 75 kg | Not permitted |

1. All mechanical rigging systems must apply a dynamic factor of 1.2 or less.



APPENDIX A: RIGGING DIAGRAMS

Dobson Rooms and Exhibition Hall Pre-Function Area





Banquet Halls and Exhibition Hall





Auditorium Pre-Function Area



Rigging Guidelines and Specifications



Auditorium



Rigging Guidelines and Specifications



Auditorium Stage House



